

QUALITY CERTIFICATE

JP 651 FR

Malmö 2016-03-02

Manufacturer declaration of conformity.

We hereby confirm that the goods are of harmonized standard.

Please see attached **TECHNICAL SPECIFICATIONS FOR DUCTING MATERIAL**.

TECHNICAL SPECIFICATIONS FOR DUCTING MATERIAL JP651FR

JP 651 FR	
Fabric:	PE 1430 Dtex
Construction:	Knitted 12x12/inch
Total weight:	Minimum 670 g/m ²
Weight test:	DIN 53 352
Tensile strength:	2100/2100 N/5 cm
Tensile test:	DIN 53 354
Tear strength:	500/500 N
Tear test:	DIN 53 363
Welding seam strength:	1900 N/5 cm
Adhesive test:	Min 100 N/5 cm DIN 53 357
Frost-resistance:	-20° C
Heat-resistance:	+70° C
Flame retardancy:	FR EN 13501-1, B-s2.d0

Tested according to ISO 11925-2:2010 for Flame retardant.

Bill Jönsson
Production Manager
JP Jensen Ventilation AB